


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 49503
 Permit No. 104
 Basin. Carson


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 38021

1. OWNER Melvin Cowparthwaite ADDRESS AT WELL LOCATION 1950 Ash Canyon Rd Carson City NV 89701
 MAILING ADDRESS 1950 Ash Canyon Rd Carson City NV 89701
 2. LOCATION NE 1/4 SW 1/4 Sec 87 T. 15 N. R. 20 E. Carson County
 PERMIT NO. 27666 8-072-37 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Existing Well				
8" to 100'				
Drilled 7/8" Hplc to 200' and Drilled Liner		100'	160'	60'
DG Sands (soft)				
Coarse DG Sands w/ Rusty Stains	XXX	160	200	40

8. WELL CONSTRUCTION
 Depth Drilled 100' Feet Depth Cased 120' Feet
 HOLE DIAMETER (BIT SIZE)
 From 7/8 Inches 100 Feet 200 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>1.88</u>	<u>80</u>	<u>200</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3X 3/32
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal N/A
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From N/A feet to N/A feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. 30-35 P.S.I.
 Water temperature Cold °F Quality Good

Date started 5-30 19 95
 Date completed 6-2 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30-35</u>	<u>40'</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Company Contractor
 Address 5651 Hwy 50 E #3 Carson City NV 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed W. Michael J. Hall
 By driller performing actual drilling on site or contractor
 Date 6-2-95