WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49525
Permit No.
Basin 230

NOTICE OF INTENT NO. 17164

1. OWNER Lyle Records
MAILING ADDRESS
ADDRESS AT WELL LOCATION Moccs Rd. ¼ mile west Power Line Rd.

2. LOCATION NE ¼ NW ¼ Sec. 7 T. 17S N/S R. 49 E. Nye County
PERMIT NO. Issued by Water Resources
19-401-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Loose Sand & Gravel | | 0 | 25 | 25 |
| Cemented Sand & Gravel | | 25 | 31 | 6 |
| Sandy Silt & Gravel | | 31 | 70 | 39 |
| Sandy Clay & Gravel | | 70 | 85 | 15 |
| Sand & Gravel | WB | 85 | 140 | 55 |

DCNR/DWR Received JAN 12 1996 LAS VEGAS OFFICE

Date started 12-18, 1995
Date completed 12-22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12¼ Inches | 0 Feet | 140 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8⅝ | 16.57 | .188 | +2 | 140 |
| | | | | |

Perforations:
Type perforation ⅛ inch by 3 inch
Size perforation SAW
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address P.O. Box 4220 Contractor
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed
By driller performing actual drilling on site or contractor
Date 1-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627