WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49526
Permit No:
Basin 089

NOTICE OF INTENT NO. 26675

1. OWNER LIGHTNING W GOLF COURSE
MAILING ADDRESS 7300 FRANKTOWN RD
CARSON CITY, NV 89704

ADDRESS AT WELL LOCATION PASTURE

2. LOCATION NE ¼ SE ¼ Sec. 22 T. 16 N/S R. 19 E. WASHOE County
PERMIT NO. 23287/20648 (Issued by Water Resources) | 055-020-61 (Parcel No.) | NONE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
THE EXISTING 12" CASING WAS RIPPED FROM 100' BELOW GL TO GL. THE WELL WAS CASED FROM +2' TO 120' W ¼ WALL 8" STEEL CASING, FROM 120' TO 300' W .080 WIRE WRAP SCREEN, FROM 300' TO 395' W DOUBLE SLOTTED, 8⅝ STEEL CASING CAPPED ON BOTTOM, W SHALE/GRAVEL TRAP AT 395'. THE WELL WAS GRAVEL PACKED FROM 100' TO 395'. THE WELL WAS GROUTED FROM 100' UP TO THE SURFACE.				

'94 JUL -8 A11:16 STATE ENGINEERS OFF

Date started 4/14, 1994
Date completed 4/24, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 553 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	CASED	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	22	¼	+2	120
8⅝	22	¼	300	395
8	—	SCREEN	120	300

Perforations:
Type perforation SAWCUT / WIRE SCREEN
Size perforation 3X 7/32 / .080
From 300 feet to 395 feet
From feet to feet
From 120 feet to 300 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 400 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow NO G.P.M. — P.S.I.
Water temperature COLD °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
CARSON CITY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reich (By driller performing actual drilling on site or contractor)
Date 6/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627