WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49538
Permit No.
Basin 179

NOTICE OF INTENT NO. 22967

1. OWNER Rodger & Shirley Hinkle
MAILING ADDRESS 5251 Cowald Court
Las Vegas NV 89118
ADDRESS AT WELL LOCATION Lot 109
250 N. Lackawana Rd.

2. LOCATION NE ¼ NE ¼ Sec. 21 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. NA (Issued by Water Resources) | 5-601-09 (Parcel No.) | Cross timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	5	
Cobbles gravel		5	7	
gravel clay conglomerate		7	28	
Cobble gravel mix		28	32	
clay		32	35	
gravel con.		35	45	
clay		45	51	
gravel con		51	66	
Sandy clay		66	70	
gravel con.		70	75	
Sandy clay		75	78	
gravel con		78	84	
Sandy clay		84	86	
gravel con		86	95	
Sandy clay		95	97	
gravel con.		97	100	
clay		100	103	
gravel con		103	106	
Sandy clay		106	108	
gravel con		108	115	
Sandy clay		115	118	
gravel	water	118	120	
Sandy clay		120	130	
gravel	water	130	136	
Sandy clay		136	139	
gravel	water	139	140	
clay		140	144	
gravel	water	144	159	
clay		159	165	

Date started June 9, 1995
Date completed July 17, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	5	1 hr

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	165 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	155

Perforations:
Type perforation Mill
Size perforation 5/8 x 2.5" x 6 row
From feet to feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 114 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address PO Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orson Maynard (By driller performing actual drilling on site or contractor)
Date July 24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627