WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49551
Permit No.
Basin

NOTICE OF INTENT NO. 16976

1. OWNER Roger Perkins
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4201 Victoria

2. LOCATION SE ¼ SE ¼ Sec. 23 T. 20S N/S R. 52 E. Nye County
PERMIT NO. 28-823-08 (Issued by Water Resources) Parcel No. Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Caliche		2	4	2
Clay		4	11	7
Caliche		11	13	2
Clay		13	25	12
Caliche		25	28	3
Clay		28	39	11
Caliche		39	41	2
Clay		41	52	11
Caliche	WB	52	55	3
Clay		55	69	14
Caliche	WB	69	72	3
Clay		72	83	11
Caliche	WB	83	85	2
Clay		85	97	12
Caliche	WB	97	100	3
Clay		100	108	8
Caliche	WB	108	110	2
Clay		110	118	8
Caliche	WB	118	123	5
Clay		123	137	14
Caliche	WB	137	140	3

DCNR/DWR Received DEC 19 1995 LAS VEGAS OFFICE

Date started November 27, 19 95
Date completed November 29, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	~~[illegible]~~ .188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1½"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR P.O. Box 8220 (Contractor)
Pahrump, NV - 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 12/13/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627