WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

OFFICE USE ONLY
Log No. 49555
Permit No.
Basin

NOTICE OF INTENT NO. 16991

1. OWNER Chuck Price
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4150 S. Oakridge Ave

2. LOCATION SE ¼ NW ¼ Sec. 1 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-131-32 (Parcel No.) Moorehead Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	11	5
Calichie		11	18	7
Clay		18	27	9
Calichie		27	29	2
Clay		29	40	11
Calichie		40	43	3
Clay		43	52	9
Calichie	WB	52	55	3
Clay		55	71	16
Calichie	WB	71	74	3
Clay		74	80	6
Calichie	WB	80	82	2
Clay		82	91	9
Calichie	WB	91	95	4
Clay		95	104	9
Calichie	WB	104	107	3
Clay		107	116	9
Calichie	WB	116	118	2
Clay		118	129	11
Calichie	WB	129	132	3
Clay		132	137	5
Calichie	WB	137	140	3

DCNR/DWR Received DEC 19 1995 LAS VEGAS OFFICE

Date started December 11, 1995
Date completed December 13, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 13"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12/13/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627