WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49558
Permit No.
Basin
NOTICE OF INTENT NO. 17287

1. OWNER Linda Elbe
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5641 Saddletree

2. LOCATION NE ¼ SE ¼ Sec. 16 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 43-081-08 (Parcel No.) Cottonwoods (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Dirt cobbles		0	5	5
Clay - Cobbles		5	37	32
Clay		37	43	6
Clay + Gravel		43	57	14
Clay Calichie		57	59	2
Clay		59	76	17
Calichie		76	78	2
Clay		78	84	6
Calichie	WB	84	87	3
Clay		87	99	12
Calichie	WB	99	102	3
Clay		102	111	11
Calichie	WB	111	113	2
Clay		113	120	7
Calichie	WB	120	122	2
Clay		122	131	9
Calichie	WB	131	148	17
Clay		148	151	3
Calichie	WB	151	164	13
~~Clay~~		~~164~~	~~175~~	~~11~~
~~Calichie~~				
Clay		164	175	11

DCNR/DWR Received DEC 29 1995 LAS VEGAS OFFICE

Date started October 12, 1995
Date completed October 16, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	175 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	175

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
(By driller performing actual drilling on site or contractor)
Date 12-11-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627