WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49560
Permit No.
Basin

NOTICE OF INTENT NO. 17330

1. OWNER Esther VanBuskirk
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 36 T 21S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	12	7
Calichie		12	16	4
Clay		16	23	6
Calichie		23	25	2
Clay		25	39	14
Calichie		39	43	4
Clay		43	52	9
Calichie		52	54	2
Clay		54	68	14
Calichie		68	71	3
Clay		71	76	5
Calichie	WB	76	80	4
Clay		80	92	12
Calichie	WB	92	95	3
Clay		95	101	6
Calichie	WB	101	112	11
Clay		112	129	17
Calichie	WB	129	132	3
Clay		132	143	11
Calichie	WB	143	146	3
Clay		146	164	18
Calichie	WB	164	167	3
Clay		167	175	8

DCNR/DWR Received DEC 19 1995 LEGAL OFFICE

Date started November 14, 1995
Date completed November 16, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	175

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From feet to feet
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address P.O. Box 4220 Contractor
Pahrump, NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 11/22/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627