

OFFICE USE ONLY
 Log No. 49569
 Permit No. _____
 Basin. 138

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22122

1. OWNER Curtis P. Hayward ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Las Vegas NV

2. LOCATION SW 1/4 SE 1/4 Sec 28 T. 20 N. S. R. 53 E. Esmeralda County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>TOP SOIL</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Caliche</u>		<u>2</u>	<u>19</u>	<u>17</u>
<u>Cemented Gravel</u>		<u>19</u>	<u>162</u>	<u>143</u>
<u>Caliche</u>		<u>162</u>	<u>165</u>	<u>3</u>
<u>Cemented Gravel</u>		<u>165</u>	<u>193</u>	<u>28</u>
<u>gravel sand</u>	<u>X</u>	<u>193</u>	<u>199</u>	<u>6</u>
<u>Granite</u>		<u>199</u>	<u>227</u>	<u>28</u>
<u>Gravel sand</u>	<u>X</u>	<u>227</u>	<u>253</u>	<u>26</u>
<u>Granite</u>		<u>253</u>	<u>270</u>	<u>17</u>

8. WELL CONSTRUCTION
 Depth Drilled 270 Feet Depth Cased 270 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 270 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>		

Perforations:
 Type perforation Factory
 Size perforation _____
 From 220 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 270 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address 181-14 West Bullion Contractor
Elko NV
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shane Bennett
 By driller performing actual drilling on site or contractor
 Date DEC-8-95

Date started Dec 8 1995
 Date completed Dec 8 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>0</u>	<u>2</u>