

OFFICE USE ONLY  
 Log No. 49571  
 Permit No. 105  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28919

1. OWNER RAY PARODI CONST. ADDRESS AT WELL LOCATION 1102 KIMMERING GARDNERVILLE  
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 20 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 27-702-05 CHAMBERS FIELD Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>cobbles-gravel w/ sandy clay</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>gravel + sand</u>		<u>5</u>	<u>38</u>	<u>33</u>
<u>cobbles + gravel w/ sandy clay</u>		<u>38</u>	<u>41</u>	<u>3</u>
<u>cobbles + gravel w/ short clay streaks</u>		<u>41</u>	<u>95</u>	<u>54</u>
<u>gravel w/ short clay streaks</u>	<u>1 H</u>	<u>95</u>	<u>140</u>	<u>45</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 100 Feet  
9 7/8 Inches 100 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.185</u>	<u>+2</u>	<u>140</u>

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3 x 3/2  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level: 37 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDICO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1535  
 Division of Water Resources, the on-site driller.  
 Signed Jerald M. Plim  
 By driller performing actual drilling on site or contractor  
 Date 10-16-95

Date started 10-10, 1995  
 Date completed 10-12, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>25+</u>	<u>—</u>	<u>1</u>

RECEIVED  
 05 NOV 13 AM 11:57  
 STATE ENGINEERS OFFICE