

OFFICE USE ONLY
 Log No. 49572
 Permit No. 105
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28918
705 MUSTANG
GARDNERVILLE

1. OWNER DARR CONSTRUCTION ADDRESS AT WELL LOCATION GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 12 N. R. 20 E DOUGLAS County
 PERMIT NO. 29-451-29 Parcel No. _____ Subdivision Name RUEHNSTROTH
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	10	10
SAND/GRAVEL		10	32	22
SANDY CLAY/GRAVEL		32	61	29
SANDY CLAY		61	101	40
SANDY CLAY/GRAVEL		101	118	17
CLAY		118	123	5
SAND/GRAVEL		123	133	10
CLAY		133	145	12
SAND/GRAVEL		145	154	9
CLAY		154	159	5
SAND/GRAVEL		159	173	14
CEMENTED/GRAVEL		173	191	18
SAND/GRAVEL		191	200	9

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 1/8 Inches 50 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 147 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 10-11, 1995
 Date completed 10-19, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20</u>	<u>—</u>	<u>4 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1997
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-19-95

RECEIVED
 95 NOV 13 AM 11:57
 STATE ENGINEERS OFFICE