

OFFICE USE ONLY
 Log No. 49573
 Permit No. R105
 Basin R105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32074
287 SHADOW MT.
GARDNERVILLE

1. OWNER MARTIN STAHL ADDRESS AT WELL LOCATION 287 SHADOW MT. GARDNERVILLE
 MAILING ADDRESS MINDEN, NV

2. LOCATION SE 1/4 SW 1/4 Sec 3 T 12 R 19 E DOUGLAS County
 PERMIT NO. 19-401-11 Parcel No. SHADOW MOUNTAIN ESTATES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG 1/2 boulders		0	80	80
DG 1/2 hard strks		80	140	60
Granite fractured		140	180	40
DG		180	185	5
Granite fractured		185	195	10
DG	✓	195	211	16
DG 1/2 hard strks	LV	211	238	27
DG 1/2 sandy clay		238	242	4

8. WELL CONSTRUCTION
 Depth Drilled 242 Feet Depth Cased 242 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 242 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>242</u>

Perforations:
 Type perforation FACTORY SLOTTED T.C.
 Size perforation 3 x 3/32
 From Factory 220 feet to 240 feet
 From T.C. 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 242 feet

9. WATER LEVEL
 Static water level: 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature: COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller
 Signed Jerrell W. Shumell
 By driller performing actual drilling on site or contractor
 Date 11-8-95

Date started 10-27, 1995
 Date completed 11-8, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>20+</u>	<u>—</u>	<u>4</u>

RECEIVED
 95 NOV 13 AM 11:57
 STATE ENGINEERS OFFICE