

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28915

1. OWNER FRED LETHER ADDRESS AT WELL LOCATION BARKER CT
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION NE 1/4 NW 1/4 Sec 32 T 13 N S R 21 E DOUGLAS County
 PERMIT NO. 23-170-13 FISH SPRINGS Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY GRAVEL/COBBLES		0	10	10
GRAVEL/COBBLES		10	13	3
SAND/GRAVEL		13	64	52
SANDY CLAY		64	75	11
CEMENTED GRAVEL		75	134	59
SANDY CLAY/GRAVEL		134	207	73
SAND		207	210	3
CLAY		210	254	44
SAND		254	265	11
CLAY		265	267	2
SANDY CLAY		267	301	34
SAND	✓	301	302	1
SANDY CLAY		302	316	14
SAND/GRAVEL	✓	316	328	12
SANDY CLAY/GRAVEL	✓	328	330	2

8. WELL CONSTRUCTION
 Depth Drilled 330 Feet Depth Cased 330 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 5 Feet
4 7/8 Inches 50 Feet 330 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>330</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 300 feet to 330 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 330 feet

9. WATER LEVEL
 Static water level 91 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 10-23, 1995
 Date completed 11-9, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIRL</u>	<u>25+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 11-9-95