WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49584
Permit No.
Basin 101

NOTICE OF INTENT NO. 30802

1. OWNER Gary Hutchings
MAILING ADDRESS 710 W. Williams AVe.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION
4833 Gallow Dr.
Fallon, Nv. 89406

2. LOCATION SE ¼ SE ¼ Sec 20 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) 08-052-66 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Coarse Sand		4	17	13
Brown Clay		17	21	4
Coarse Sand	XX	21	24	3
Clay		24	25	1
Coarse Sand		25	29	4
Clay		29	33	4

RECEIVED 95 DEC 14 AM 11:03 STATE ENGINEER'S OFFICE

Date started Nov. 21, 19 95
Date completed Nov. 21, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	33 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	33

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 28 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 25 FEET
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [XX] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 32 feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 12-11-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627