WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49587
Permit No.
Basin 104

NOTICE OF INTENT NO. 30798

1. OWNER Mike Casey
MAILING ADDRESS 1550 Allen Rd.
Fallon, Nv. 89406

ADDRESS AT WELL LOCATION 14865 Springflower Lane
Fallon, Nv. 89406

2. LOCATION ~~NE~~ ¼ ~~NW~~ ¼ Sec 27 ~~25~~ T 19 X/S R 26 E Churchill County
PERMIT NO. SW SW SW (Issued by Water Resources) | 7-171-70 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse SAnd		0	21	21
Brown Clay		21	23	2
Coarse Sand Gravel		23	30	7
Brown Sandy Clay		30	40	10
Coarse SAnd		40	42	2
Brown Sandy Clay		42	78	36
Brown Clay		78	95	17
Brown Sandy Clay		95	100	5
Coarse Sandy Clay		100	118	18
Brown Sandy Clay		118	135	17
Coarse Sandy Clay		135	141	6
Coarse Sand Gravel	XX	141	144	3
Gray Clay		144	145	1

Date started Nov. 17, 19 95
Date completed Nov. 18, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8-3/4 Inches	50 Feet	145 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	145

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 125 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons (By driller performing actual drilling on site or contractor)
Date 12-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627