WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49588
Permit No.
Basin 101

NOTICE OF INTENT NO. 30800

1. OWNER Mike Casey
MAILING ADDRESS 1550 Allen Rd.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION 15005 Spring Flower Ln.
Fallon, NV. 89406

2. LOCATION NW ¼ NW ¼ Sec 27 25 T 19 XXS R 26 E Churchill County
PERMIT NO. SW SW SW (Issued by Water Resources) 07-071-71 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Rock		0	7	7
Black Gravel		7	26	19
Sand		26	29	3
Brown Sandy Clay		29	37	8
Coarse Sand		37	40	3
Brown Sandy Clay		40	60	20
Sand		60	63	3
Brown Sandy Clay		63	80	17
Sand Gravel		80	84	4
Brown Sandy Clay		84	137	53
Coarse Sand Gravel	XX	137	150	13
Brown Clay		150	154	4

RECEIVED 95 DEC 14 AM 1:02 STATE ENGINEER'S OFFICE

Date started Nov. 20, 1995.
Date completed Nov. 20, 1995.

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 154 Feet Depth Cased 154 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8-3/4 Inches		50 Feet	154 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	154

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 134 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 154 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons (By driller performing actual drilling on site or contractor)
Date 12-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627