WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47605
Permit No. 60671
Basin

NOTICE OF INTENT NO. 13226

1. OWNER JOHN + TINA GOSS
MAILING ADDRESS

ADDRESS AT WELL LOCATION OLETA + JONES

2. LOCATION SE ¼ NE ¼ Sec. 23 T 22 N/S R 60 E CLARK County
PERMIT NO. 60671 (Issued by Water Resources) 176-23-601-010 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND + ROCKS | | 0 | 10 | 10 |
| CMT GRAVEL | | 10 | 120 | 110 |
| CMT GRAVEL | | 120 | 400 | 280 |
| W/STRKS SANDSTONE | | | | |
| SANDSTONE | 430 | 400 | 510 | 110 |
| CMT. GRAVEL. | | 510 | 560 | 50 |

RECEIVED
APR 26 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-14, 1995
Date completed 4-19, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 14 3/4 Inches | 0 Feet | 60 Feet |
| 12 1/4 Inches | 60 Feet | 560 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +1 | 560 |

Perforations:
Type perforation FACTORY SAW
Size perforation 1/8 x 2 1/2
From 500 feet to 540 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 80 feet to 560 feet

9. WATER LEVEL
Static water level 355 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING (Contractor)
Address 6475 GARY AVE (Contractor)
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1966
Signed Lyndall Cousb
By driller performing actual drilling on site or contractor
Date 4-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627