

OFFICE USE ONLY
 Log No. 49606
 Permit No. 084
 Basin 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31873

1. OWNER William F. Cass ADDRESS AT WELL LOCATION 076-080-44
 MAILING ADDRESS 12725 Martha Ann Dr.
Los Alamitos, Ca 90720

2. LOCATION SW 1/4 NW 1/4 Sec. 18 T 21 N N/S R 22 East Washoe County
 PERMIT NO. 076-080-44 Palimino Valley Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	6	
Black volcanic rock (fractured)		6	23	
Tan Clay		23	51	
Green Clay		51	72	
Green Clay w/some Black Volcanic rock		72	85	
Black, White Volcanic rock Trace green clay		85	120	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 55 Feet
8-1/2 Inches 55 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1-1/2</u>	<u>120</u>

Perforations:
 Type perforation Factory-Sawed
 Size perforation 3/32 x 3
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 120 feet to 50 feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality good

Date started 12-6- 1995
 Date completed 12-6- 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30 +</u>		<u>2hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800-1/2 Frazer Avenue Contractor
Sparks, Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed Larry Welch
 By driller performing actual drilling on site or contractor
 Date December 8, 1995