WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49611
Permit No.
Basin 103

NOTICE OF INTENT NO. 28025

1. OWNER Dallas Cook
MAILING ADDRESS 519 Rocky Dayton NV.
ADDRESS AT WELL LOCATION 519 Rocky Dayton NV.

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. (Issued by Water Resources) 16-151-09 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dryed Brown Clays		0	20	20
Course Cobbles		20	22	2
Brown Clays		22	63	41
Brown/Red Clays		63	110	47
Course Volcanic Sands		110	127	37
Red Volcanic Clay		127	175	48
Course Sands Volcanic Gravels Red Clays	XXX	175	200	25

RECEIVED 95 NOV 28 PM 4:45 STATE ENGINEER'S OFFICE

Date started 11-22, 1995
Date completed 11-23, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E. #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall (By driller performing actual drilling on site or contractor)
Date 11-23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627