WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49612 In Book
Permit No.
Basin 162

NOTICE OF INTENT NO. 13186

1. OWNER Raymond J. Walker
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 21-S N/S R 54 E Nye County
PERMIT NO. APN 45-371-06 (Issued by Water Resources) 998 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Clay/Broken Caliche		4	48	44
Soft Sandy Clay		48	56	8
Clay/Broken Caliche		56	118	62
Hard Limestone		118	124	6
Soft Brown Clay	x	124	136	12
Brown Clay		136	160	24
Grey Clay		160	216	56
Hard Limestone		216	221	5
Brown Clay		221	248	27
Hard Limestone		248	255	7
Brown Clay		255	260	5

RECEIVED DEC 18 1995 NEVADA DIVISION OF WATER RESOURCES

Date started Nov. 8, 1995
Date completed Nov. 18, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	260

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 120 feet to 140 feet
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 Pahrump 89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date DEc. 14, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627