

OFFICE USE ONLY  
Log No. 49623  
Permit No. \_\_\_\_\_  
Basin 288  
NOTICE INTENT NO. 16264

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Cody Young ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS Box 6443 \_\_\_\_\_  
Elko NV 89802 \_\_\_\_\_  
2. LOCATION SW 1/4 SW 1/4 Sec 14 T 33 N S R 55 E Elko County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_ Parcel No. 10-F Subdivision Name Western Hills

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Clay with large cobbles</u>		<u>3</u>	<u>85</u>	<u>82</u>
<u>Sandy clay</u>		<u>82</u>	<u>350</u>	<u>268</u>
<u>Cemented sand with x</u>		<u>268</u>	<u>510</u>	<u>242</u>
<u>Basalt layers</u>				
<u>Sand stone</u>	<u>X</u>	<u>510</u>	<u>600</u>	<u>90</u>

8. WELL CONSTRUCTION  
Depth Drilled 600 Feet Depth Cased 600 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 600 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>600</u>

Perforations:  
Type perforation M.11 slot  
Size perforation \_\_\_\_\_  
From 530 feet to 590 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 52  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 52 feet to 600 feet

9. WATER LEVEL  
Static water level 4.25 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60.2 °F Quality good

Date started Oct 2, 1995  
Date completed Oct 20, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AAA Drilling Contractor  
Address Box 2487 Contractor  
Elko NV 89802  
Nevada contractor's license number issued by the State Contractor's Board 002684  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783  
Signed Log R. Ouffield  
By driller performing actual drilling on site or contractor  
Date Oct 30 1995