

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31192

1. OWNER Stan Gallin ADDRESS AT WELL LOCATION 3400 TAFZYN Rd  
 MAILING ADDRESS 4175 Reno Hwy  
Fallon  
 2. LOCATION SE 1/4 NE 1/4 Sec. 8 T. 19 N/S R. 29 E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	19	19
Brown Clay		19	23	4
Grey sands	Y	23	50	27
Black silt		50	72	22
Grey sands		72	80	8
Grey clay		80	83	3
Grey sands		83	87	4
Brown clay		87	90	3
Brown sands	X	90	102	12

8. WELL CONSTRUCTION  
 Depth Drilled 102 Feet Depth Cased 102 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 50 Feet  
 From 6 1/8 Inches To 102 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17.9</u>	<u>1/8</u>	<u>+1</u>	<u>102</u>

Perforations:  
 Type perforation machine cut  
 Size perforation 0.80  
 From 95 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 6' 4" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality OK

Date started 11-3, 1995  
 Date completed 11-3, 1995

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>30</u>	<u>1 hr</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Corp Contractor  
 Address 335 N Broadway Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 11753  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
 Signed Jesus Manicor  
 By driller performing actual drilling on site or contractor  
 Date 11-3-95