

Log No. 49629  
Permit No. 101  
Basin. 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29625

1. OWNER KAREN KOZETTE ADDRESS AT WELL LOCATION 4445 Reno Hwy  
MAILING ADDRESS 4445 Reno Hwy

2. LOCATION SE 1/4 NE 1/4 Sec. 28 T. 19 N/S R. 28 E Churchill County  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	18	18
Brown Clay		18	20	2
Brown Sand	X	20	32	12
Grey Sand		32	60	28
Black Silt		60	71	11
Grey Sands		71	84	13
Grey Clay		84	86	2
Brown Sands	Y	86	96	10

8. WELL CONSTRUCTION  
Depth Drilled 96 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)  
From 0 To 50 Feet  
10 3/4 Inches 0 Feet 50 Feet  
6 1/8 Inches 50 Feet 96 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17.9</u>	<u>1/8</u>	<u>+1</u>	<u>96</u>

Perforations:  
Type perforation machine cut  
Size perforation 080  
From 89 feet to 54 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 8' 9" feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60.2 °F Quality OK

Date started 11-17-1995  
Date completed 11-17-1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>		<u>1</u>	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WELSCO CORP Contractor  
Address 335 N Broadway Contractor  
Nevada contractor's license number issued by the State Contractor's Board 11752  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
Signed Jean Manigault  
By driller performing actual drilling on site or contractor  
Date 11-17-95