WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49630
Permit No.
Basin

NOTICE OF INTENT NO. 16922

1. OWNER Hughes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1191 Deerskin

2. LOCATION SW ¼ NE ¼ Sec. 35 T 20 S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 42-693-10 (Parcel No.) Caliuada Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	11	6
Calichie		11	14	3
Clay		14	19	5
Calichie		19	22	3
Clay		22	34	12
Calichie		34	36	2
Clay		36	43	7
Calichie		43	45	2
Clay		45	51	6
Calichie	WB	51	53	2
Clay		53	60	7
Calichie	WB	60	63	3
Clay		63	70	7
Calichie	WB	70	74	4
Clay		74	89	15
Calichie	WB	89	91	2
Clay		91	104	13
Calichie	WB	104	106	2
Clay		106	113	7
Calichie	WB	113	115	2
Clay		115	128	13
Calichie	WB	128	131	3
Clay		131	137	6
Calichie	WB	137	140	3

Date started January 4, 1996
Date completed January 8, 1996

DCNR/DWR Received JAN 16 1996 LAS VEGAS OFFICE

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 1-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627