WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49634
Permit No.
Basin 162

NOTICE OF INTENT NO. 17459

1. OWNER Brian Holt
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1431 Curtis Court

2. LOCATION SE ¼ NW ¼ Sec 21 T 20S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 39-162-22 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	12	6
Calichie		12	15	3
Clay		15	26	11
Calichie		26	29	3
Clay		29	35	6
Calichie		35	38	3
Clay		38	54	16
Calichie	WB	54	57	3
Clay		57	69	12
Calichie	WB	69	72	3
Clay		72	81	9
Calichie	WB	81	83	2
Clay		83	94	11
Calichie	WB	94	96	2
Clay		96	102	6
Calichie	WB	102	105	3
Clay		105	121	16
Calichie	WB	121	123	2
Clay		123	134	11
Calichie				

DCNR/DWR Received JAN 15 1996 LAS VEGAS OFFICE

Date started December 26, 19 95
Date completed December 28, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From feet to feet
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
~~Gre~~ Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 1-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627