WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49638
Permit No.
Basin 162

NOTICE OF INTENT NO. 16995

1. OWNER Ed Peart
MAILING ADDRESS
ADDRESS AT WELL LOCATION ~~Kisha~~ 8290 S. Cottontail

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-391-01 (Parcel No.) Fox Hollow (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	7	3
Clay		7	13	6
Calichie		13	16	3
Clay		16	32	16
Calichie		32	36	4
Clay		36	43	7
Calichie		43	45	2
Clay		45	57	12
Calichie	WB	57	59	2
Clay		59	66	7
Calichie	WB	66	68	2
Clay		68	77	9
Calichie	WB	77	81	4
Clay		81	89	8
Calichie	WB	89	92	3
Clay		92	107	15
Calichie	WB	107	109	2
Clay		109	117	8
Limestone	WB	117	125	8
Calichie	WB	125	129	4
Clay		129	139	10
Calichie	WB	139	140	1

RECEIVED JAN 16 1996 LAS VEGAS OFFICE

Date started December 14, 1995
Date completed December 18, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8		
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3/4"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box ~~1052~~ 4220 (Contractor)
Pahrump N. 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas D. (By driller performing actual drilling on site or contractor)
Date 1-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627