

OFFICE USE ONLY
 Log No. 49643
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 16988

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Scott Duncan ADDRESS AT WELL LOCATION 2781 Shadow Mtn.
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SW 1/4 Sec. 6 T. 20S N/S R. 53 E. Nye County
 PERMIT NO. 36-533-04 Shadow Mtn. Est. Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	60	60
Caliche	WB	60	62	2
Clay		62	70	8
Caliche	WB	70	73	3
Clay		73	95	22
Caliche	WB	95	98	3
Clay		98	115	17
Caliche	WB	115	119	4
Clay		119	128	9
Caliche	WB	128	130	2
Clay		130	138	8
Caliche	WB	138	140	2

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.99</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw cut
 Size perforation 2 1/8 x 3
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address P.O. Box 4220 Contractor
Rahrum, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 12/16/95

Date started December 11 1995
 Date completed December 13 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

