WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49665
Permit No.
Basin 083

NOTICE OF INTENT NO. 25687

1. OWNER Age Corporation
MAILING ADDRESS P.O. Box 7475 Reno
ADDRESS AT WELL LOCATION 455 East Mustang Sparks NV

2. LOCATION NW ¼ NE ¼ Sec. 15 T. 19 N/S R. 21 E. Storey County
PERMIT NO. 50536 (Issued by Water Resources) 04-111-04 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Gravel		0	12	12
Gravel, to 2"	✓	12	43	31
Clay, brown, Sandy		43	67	24
Clay, Pink, tan		67	114	47
Gravel	✓	114	119	5
Clay, Grey		119	129	10
Gravel, to 3/4"		129	131	2
Clay tan, Sandy		131	182	51
Gravel, to 1/2"	✓	182	189	7
Shale, dark, Grey		189	227	38
Rock, black		227	231	5
Gravel, to 3/4"		231	236	5
Shale Grey		236	312	76
Shale, brown, Sandy		312	350	38

Date started 5-9, 1995
Date completed 5-17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	—	6

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	200 Feet
7 7/8 Inches		200 Feet	350 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	0.188	0	200

Perforations:
Type perforation factory mill slot
Size perforation 3/32
From 115 feet to 135 feet
From 175 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 72 °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 2290 Pioneer Drive (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1261
Signed Steve [illegible] (By driller performing actual drilling on site or contractor)
Date 6/27/95

RECEIVED JUN 30 '95 AM 8:38 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627