

OFFICE USE ONLY  
 Log No. 496723  
 Permit No. \_\_\_\_\_  
 Basin. 8-101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27053

1. OWNER Ullie Bartel ADDRESS AT WELL LOCATION 5156 Sandalwood  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. 05-651-80 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name Copperwood

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand	✓	0	20	20
Brown Clay	✓	20	23	3
Brown Sand	✓	23	34	11
Grey Sand	✓	34	47	13
Black Silt	✓	47	67	20
Grey Sand	✓	67	79	12
Brown Sand	✓	79	87	8

8. WELL CONSTRUCTION  
 Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
 From 6 Inches To 87 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>41</u>	<u>87</u>

Perforations:  
 Type perforation machine slot  
 Size perforation .070  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 81 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started July 30 1994  
 Date completed July 3 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1</u>

Name Wesco Contractor  
 Address Box 888 Fallon Nev. Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date Oct 12-94