

OFFICE USE ONLY  
 Log No. 49679  
 Permit No. \_\_\_\_\_  
 Basin 092A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23812

1. OWNER STEVE & WENDY KELLER ADDRESS AT WELL LOCATION 11400 WAGON HO  
 MAILING ADDRESS 11400 WAGON HO RENO NV 89506

2. LOCATION NW 1/4 SE 1/4 Sec. 25 T 21N N/S R. 18 E E WASHOE County  
 PERMIT NO. 086-370-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
STICKY GREEN CLAY		64	74	
COARSE SANDS & GRAVEL		74	81	
GREEN WHITE BROWN				
STICKY GREEN CLAY		81	93	
FINE DG SANDS				
GREEN WHITE BROWN		93	102	
STICKY GREEN CLAY		102	110	
COARSE SAND & GRAVELS				
GREEN BROWN WHITE		110	115	
STICKY GREEN CLAY		115	127	
COARSE SANDS & GRAVEL				
GREEN BROWN WHITE		127	136	
STICKY GREEN CLAY		136	144	
144 TD				

8. WELL CONSTRUCTION  
 Depth Drilled 144 Feet Depth Cased 144 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 7 7/8 Inches To 6 1/4 Feet 144 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	44	144

Perforations:  
 Type perforation FACTORY SAWED  
 Size perforation 3/32 x 3"  
 From 134 feet to 114 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal IN PLACE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 45 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. PUMP & WELL SERVICE INC  
 Contractor  
 Address 1800 1/2 FRAZER AVENUE  
 Contractor  
SPARKS, NEVADA 89431

Nevada contractor's license number issued by the State Contractor's Board ### 35387A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed James A. Welch  
 By driller performing actual drilling on site or contractor  
 Date 7-21-95

Date started 7-17 1995  
 Date completed 7-18 1995

7. WELL TEST DATA

TEST METHOD  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		2 1/2