


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.349



Log No. \_\_\_\_\_  
 Permit No. 1912  
 Basin \_\_\_\_\_

NOTICE OF INTENT NO. 12747

1. OWNER Scott Stevens ADDRESS AT WELL LOCATION Monroe & Bledsoe  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NW 1/4 Sec 28 T. 20 N/S R. 60 E Clark County  
 PERMIT NO. 250-251-011  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_


3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clayey Soil</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Brown Clay</u>		<u>8</u>	<u>18</u>	<u>10</u>
<u>Caliche</u>		<u>18</u>	<u>22</u>	<u>4</u>
<u>White Clay</u>		<u>22</u>	<u>60</u>	<u>38</u>
<u>Tan Gritty Clay</u>		<u>60</u>	<u>200</u>	<u>140</u>



8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>.188</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Milled Slots  
 Size perforation 1/8 x 2 1/2 x 8 Rows  
 From 120 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet



9. WATER LEVEL  
 Static water level 69 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Good

Date started April 24, 1995  
 Date completed April 27, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>		<u>30 min</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thompson Drilling Co., Inc Contractor  
 Address 4185 W. Harmon Contractor  
Las Vegas NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 4286A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_