WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49692
Permit No.
Basin 162

NOTICE OF INTENT NO. 17108

1. OWNER Larry Graff
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4080 Pawnee Place

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-312-05 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Calichie		0	3	3
Clay		3	30	27
Calichie		30	33	3
Clay		33	43	10
Calichie		43	45	2
Clay		45	60	15
Calichie	WB	60	63	3
Clay		63	71	8
Calichie	WB	71	75	4
Clay		75	88	13
Calichie	WB	88	90	2
Clay		90	98	8
Calichie	WB	98	100	2
Clay		100	115	5
Calichie	WB	115	118	3
Clay		118	125	6
Calichie	WB	125	129	4
Clay		129	136	7
Calichie	WB	136	140	4

DCNR/DWR Received NOV 17 1995 LAS VEGAS OFFICE

Date started October 9, 1995
Date completed October 11, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 11-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627