



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16766  
 ADDRESS AT WELL LOCATION 4300 Navajo Street  
Pahrump, NV 89041

1. OWNER Flancois James ADDRESS AT WELL LOCATION 4300 Navajo Street  
 MAILING ADDRESS 4300 Navajo Street  
Pahrump, NV 89041

2. LOCATION NE 1/4 NW 1/4 Sec 20 T 21S N/S R 54 E Nye County Green Valley  
 PERMIT NO. 45-281-26 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	4	4
Calachiea		4	8	4
Blown Clay		8	47	39
Calachiea		47	50	3
Blown Clay		50	56	6
Calachiea	X	56	62	6
Blown Clay	X	62	120	58
Grey Clay	X	120	140	20

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 140 Feet  
 From 0 Feet To 140 Feet  
 From 0 Feet To 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18	203	0	140

Perforations:  
 Type perforation Factory  
 Size perforation 1/4 x 4

From 100 feet to 120 feet  
 From        feet to        feet  
 From        feet to        feet  
 From        feet to        feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED

OCT 25 1995

DCNB/DWR  
 LAS VEGAS OFFICE

Date started October 31 SEPT 27 19 95  
 Date completed September OCT. 3 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	NA	1/2

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow        G.P.M.        P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Jenkins Contractor  
 Address P. O. Box 3392 Contractor  
Pahrump, NV 89041

Nevada contractor's license number 0035901  
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor

Date OCT. 10 - 1995

