WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

DCNR/DWR Received NOV 1 1995 LAS VEGAS OFFICE

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 49720
Permit No.
Basin 162

NOTICE OF INTENT NO. 17078

1. OWNER Spangle
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2570 Retreat

2. LOCATION NE ¼ SW ¼ Sec. 18 T 20 N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 36-201-27 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	8	4
Calichie		8	11	3
Clay		11	27	16
Calichie		27	29	2
Clay		29	36	7
Calichie		36	38	2
Clay		38	54	16
Calichie	WB	54	56	2
Clay		56	68	12
Calichie	WB	68	71	3
Clay		71	101	30
Calichie	WB	101	104	3
Clay		104	115	11
Calichie	WB	115	119	4
Clay		119	128	9
Calichie	WB	128	131	3
Clay		131	137	6
Calichie	WB	137	140	3

Date started August 30, 1995
Date completed 9/1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (Be driller performing actual drilling on site or contractor)
Date 10/23/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627