

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY



STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 49721
 Permit No. _____
 Basin 163

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17063

1. OWNER Chris Allen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HCR 31 Box 85 Emerald Ave.
Sandy Valley, NV. 89019
 2. LOCATION NE 1/4 NW 1/4 Sec. 22 T. 24 S. N/S R. 56 E Clark County
 PERMIT NO. 580-160-019 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	10	10
CALICHE		10	13	13
CLAY		13	30	17
CEMENTED SAND+GRAVEL		30	36	6
CLAY+GRAVEL		36	60	24
CEMENTED SAND+GRAVEL		60	70	10
CLAY+GRAVEL		70	80	10
CALICHE		80	88	8
CEMENTED SAND+GRAVEL		88	120	32
CLAY+GRAVEL		120	140	20
CALICHE	W.B	140	145	5
CLAY		145	165	20
CALICHE	W.B	165	175	10
CLAY		175	183	8
CALICHE	W.B	183	192	9
CLAY		192	200	8

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 3/8 INCH BY 3/8 INCH
 From 200 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 200 feet to 50 feet

9. WATER LEVEL
 Static water level 105 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 9-28, 1995
 Date completed 10-11, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. Box 3505 Contractor
PAHRUMP NV. 89041
 Nevada contractor's license number 40020 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1573
 Signed Winnie Brown
 By driller performing actual drilling on site or contractor
 Date 10-16-95