


WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY



STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49726
Permit No. _____
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 16698

1. OWNER Alton Albin ADDRESS AT WELL LOCATION: 1151 E. Deerskin St.
MAILING ADDRESS: _____

2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 35 T 20-S N/S R 53 E. Nye County
PERMIT NO. 42-693-11 Parcel No. Calvada Valley Unit: 3 Blk: 29
Issued by Water Resources Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	8	4
Brown clay & caliche		8	29	21
Brown clay		29	42	13
Brown clay & caliche		42	56	14
Brown clay	X	56	81	25
Brown clay & caliche		81	104	14
Brown clay	X	104	118	14
Brown clay & caliche		118	140	22

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From To
12 Inches 0 Feet 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18.26	.203	0	100
8 5/8	16.94	.188	100	140

Perforations:
Type perforation Torch Cut
Size perforation 1" width 8" long
From 100 feet to 140 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level: 39 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started October 9, 1995
Date completed October 9, 1995

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC Contractor
Address P.O. Box 56 Contractor
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board: 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1812

Signed Jim A. Pike
By driller performing actual drilling on site or contractor

Date October 18, 1995