



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 49728  
 Permit No. \_\_\_\_\_  
 Basins \_\_\_\_\_  
 NOTICE OF INTENT NO. 16769

1. OWNER Ross Flazie ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1280 E. Gamebird 1400 E. Rancho View Drive  
Pahrump, NV 89041 Pahrump, NV 89041  
 2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 21S N/S R. 53 E. Nye County \_\_\_\_\_  
 PERMIT NO. 44-211-15 Rancho View Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Stock  Test  Other \_\_\_\_\_  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blown Clay		0	6	6
Calachiea		6	12	6
Blown Clay		12	22	10
Calachiea		22	25	3
Blown Clay	X	25	96	71
Calachiea	X	96	99	3
Grey Clay	X	99	140	41

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18	203	0	140

Perforations:  
 Type perforation Factory  
 Size perforation 1/4 X 4  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 72 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started October 1, 19 95  
 Date completed September 2 OCT. 3, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	40	NA	1/2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry Jenkins Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number 0035901  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1916  
 Division of Water Resources the on-site driller.  
 Signed Larry Jenkins  
 By Driller performing actual drilling on site or contractor  
 Date OCT. 10 - 1995

RECEIVED  
 OCT 25 1995  
 DCNR/DWR  
 LAS VEGAS OFFICE

