

OFFICE USE ONLY
 Log No. 49733 & 49735
 Permit No. 1
 Basin 061
 NOTICE OF INTENT NO. 29501

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE
 MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 36 N S R. 50 E EUREKA County
 PERMIT NO. M/0-441A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BOULDERS & FILL		0	7	7
CARLIN		7	240	233
CLAYS, SAND, GRAVEL & CARLIN	10 GPM	240	320	80
CARLIN	60 GPM	320	460	140
CARLIN FORMATION	120 GPM	460	715	255
VINNINI	150 GPM	715	775	60

8. WELL CONSTRUCTION
 Depth Drilled 775 Feet Depth Cased 774 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12-1/4 Inches 0 Feet 20 Feet
6-1/8 Inches 20 Feet 775 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	28.5	.322	0	20
#1 1-1/4	2	SCH 80	0	674
#2 1-1/4	2	SCH 80	0	358

Perforations: DRILLED HOLES
 Type perforation
 Size perforation .125
 From #1 674 feet to 774 feet
 From #2 358 feet to 398 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 121 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 347,660 feet to 412,775 feet

9. WATER LEVEL
 Static water level (#1 583') (#2 132) _____ feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 56 °F Quality _____

Date started JULY 21, 1995
 Date completed JULY 24, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
 Signed MARK WAITE *Mark Waite*
 By driller performing actual drilling on site or contractor
 Date AUGUST 17, 1995

RECEIVED
 95 AUG 28 PM 2:23
 STATE ENGINEERS OFFICE