PZ-95-7

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49738 & 49739
Permit No.
Basin 061

NOTICE OF INTENT NO. 29502

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NE ¼ Sec. 30 T 36 (N) S R 50 E EUREKA County
PERMIT NO. M/O-441A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	96	96
WEATHERED GRANITE		96	210	114
CLAY ALTERED		210		
GRANITE DIORITE			360	150
FRACTURED GRANITE	20 GPM	360	550	190
GRANITE	50 GPM	550	810	260

Date started AUGUST 1, 1995
Date completed AUGUST 3, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 810 Feet Depth Cased 798 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches		0 Feet	101.5 Feet
6-1/2 Inches		101.5 Feet	810 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	101.5
#1 1-1/4	2	SCH 40	0	358
#2 1-1/4	2	SCH 40	0	734

Perforations:
Type perforation DRILLED HOLES
Size perforation .125
From #1 358 feet to 438 feet
From #2 734 feet to 798 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 340, 725 feet to 447, 810 feet

9. WATER LEVEL
Static water level (#1 335') (#2 346') feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 56 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed MARK WIATE Mark Wiate
By driller performing actual drilling on site or contractor
Date AUGUST 18, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627