

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY
 M/O 384305-1
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 44743
 Permit No.
 Basin 066

NOTICE OF INTENT NO. 15675

1. OWNER SANTA FE PACIFIC GOLD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 861 W. 6th ST
WIND, N.J. 89443
 2. LOCATION NE 1/4 NW 1/4 Sec. 5 T. 38 N. R. 43 E. HUMBOLDT County
 PERMIT NO. M/O 933 Parcel No. 7-131-03 Subdivision Name _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIUM				
SAND, CLAY, GRAVEL		0	160	160
SAND PACKED		160	172	14'
3/8" Bentonite pellets		12	10	2
NEAT Cement		10	0	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/2 Inches To 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>SCH 80</u>	<u>P.V.C BLANK</u>	<u>40</u>	<u>0</u>

Perforations:
 Type perforation 2.5" SCH 80 P.V.C screen
 Size perforation .020
 From 40 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 12 feet to 160 feet

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND DRILLING Contractor
 Address P.O. Box 2786 ELKO NV. 89803 Contractor

Date started 6-17, 1995
 Date completed 6-18, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80'</u>	<u>8</u>		<u>1/2</u>

Nevada contractor's license number 0030823
 issued by the State Contractor's Board 0019378
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1788
 Signed Jak Welch
 By driller performing actual drilling on site or contractor
 Date 6-19-95