#95-101

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49755
Permit No.
Basin 066

NOTICE OF INTENT NO. 29572

1. OWNER FIRSTMISS GOLD INC.
MAILING ADDRESS P.O. BOX 220
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION
FIRSTMISS - GETCHELL MINE SITE

2. LOCATION NW ¼ NE ¼ Sec 33 T 39 N/S R 42 E HUMBOLDT County
PERMIT NO. M/O-920 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BASALT		0	2260	2260
LOW SEDIMENTS		2260	2502	242

*WELL BORE WAS CEMENTED WITH 16 LB/GAL SLURRY FROM 1,355 FT TO 2,502 FEET.

95 JUN 21 AM 10:28
STATE ENGINEER

Date started MAY 24, 1995
Date completed MAY 28, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2502 Feet Depth Cased 1300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	20	Feet
6-1/4	Inches	20	Feet	2,502	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28.57	.250	0	20
5	14.62	.258	0	640
1-1/4	2.27	.140	+1.5	1,100

Perforations:
Type perforation MILL SLOT
Size perforation .020
From 1,100 feet to 1,300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 530
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1035 feet to 1355 feet

9. WATER LEVEL
Static water level 285 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1939

Signed KEVIN ELLISON Kevin Ellison
By driller performing actual drilling on site or contractor

Date JUNE 15, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627