#95-94

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49757
Permit No.
Basin 066

NOTICE OF INTENT NO. 29568

1. OWNER FIRST MISS - GETCHEL MINE
MAILING ADDRESS P.O. BOX 220
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION
GETCHEL MINE

2. LOCATION SW ¼ NE ¼ Sec 33 T 39 (N)S R 42 E HUMBOLDT County
PERMIT NO. M/O - 920 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BASALT		0	105	
MARBLE & HORNFELS		105	180	
BASALT		180	503	
HORNFELS, MARBLE & SKARN		503	2288	
BLACK HORNFELS & MARBLE		2288	3017	
NOTE				
CORE HOLE, PZ WELL				
GRAVEL PACKED		3017	2540	
FINE SAND		2540	2525	
ABANDONITE PUMPED		2525	400	
3/8 HOLE PLUG		400	0	

Date started JUNE 19, 1995
Date completed JUNE 23, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20 GALLONS PER HOUR		

8. WELL CONSTRUCTION
Depth Drilled 3017 Feet Depth Cased 3000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7-5/8 Inches		0 Feet	40 Feet
6 Inches		40 Feet	400 Feet
4 Inches		400 Feet	3017 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	18.97	1/8	0	40
5	14.62	1/4	0	400
1-1/4	3.0	SCHEDULE 80	0	2600

Perforations:
Type perforation SLOT
Size perforation .125
From 2600 feet to 3000 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 400
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout HOLE PLUG
Gravel Packed: [X] Yes [ ] No
From 3017 feet to 2540 feet

9. WATER LEVEL
Static water level 635 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed JOHN VIERGUTZ (By driller performing actual drilling on site or contractor)
Date JUNE 28, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627