DW-1

X WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49758
Permit No.
Basin OGB

NOTICE OF INTENT NO. 28767

1. OWNER FIRSTMISS GOLD INC.
MAILING ADDRESS P.O. BOX 220
GOLCONDA, NEVADA 89414

ADDRESS AT WELL LOCATION
FIRSTMISS - GETCHELL MINE SITE

2. LOCATION NW ¼ NE ¼ Sec. 33 T. 39 (N)S R. 42 E. HUMBOLDT County
PERMIT NO. 61201T & 61202T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN ROCK		0	270	270
BASALT HARD GRAY ROCK		270	375	105
GRAY CLAY		375	380	5
BASALT HARD GRAY ROCK		380	570	190
CLAY, SOME ROCK		570	600	30
BASALT HARD GRAY ROCK		600	790	190
50% CLAY, BLACK ROCK		790	800	10
FRACTURED BLACK ROCK		800	880	80
BASALT HARD BLACK ROCK		880	1280	400
CLAYS AND BLACK ROCK		1280	1600	320
HARD BLACK ROCK		1600	1675	75
CLAYS/ BLACK ROCK		1675	1800	125
HARD BLACK ROCK		1800	1850	50
CLAYS / BLACK ROCK AND		1850		
SMALL FRACTURES			2242	392

Date started MAY 16, 19 95
Date completed JUNE 10, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2242 Feet Depth Cased 2238 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
30	Inches	0	Feet	59	Feet
21	Inches	59	Feet	2,242	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	125	.250	0	59
12	49.5	.375	0	355
12	49.5	.375	1,116	1,196
12	49.5	.375	1,757	1,837

Perforations:
Type perforation ROSCO MOSS FULL FLOW LOUVERED
Size perforation
From 355 feet to 1,116 feet
From 1,196 feet to 1,757 feet
From 1,837 feet to 2,238 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 59
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 59 feet to 2,242 feet

9. WATER LEVEL
Static water level 263 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 64 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1822
Signed ROD THOMPSON Rod Thompson
By driller performing actual drilling on site or contractor
Date JULY 17, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627