PW-9

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49764
Permit No.
Basin 031

NOTICE OF INTENT NO. 6397

1. OWNER AMAX GOLD INC.
MAILING ADDRESS 600 SOD HOUSE ROAD
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION SE ¼ SW ¼ Sec 16 T 40 N/S R 35 E HUMBOLDT County
PERMIT NO. 49764 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ALL BUT 54.7 FT OF ORIGINAL WELL HAS BEEN | | | | |
| MINED AWAY BY THE OPEN PIT. THE BOTTOM 54.7 FT | | | | |
| WAS CLEANED OUT AND THEN FILLED WITH 16 LB/GAL | | | | |
| CEMENT SLURRY TO SURFACE. | | | | |

Date started JUNE 22, 1995
Date completed JUNE 22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 298 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 19-1/2 Inches | 0 Feet | 298 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | | .250 | 0 | 100 |
| 12 | | .250 | 120 | 180 |

Perforations:
Type perforation JOHNSON HI-CAP
Size perforation 50 - SLOT
From 100 feet to 120 feet
From 180 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 298 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed JOHN VIERGUTZ (By driller performing actual drilling on site or contractor)
Date JULY 17, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627