PW-60

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49765
Permit No. 56413
Basin

NOTICE OF INTENT NO. 29565

1. OWNER AMAX GOLD INC.
MAILING ADDRESS 600 SOD HOUSE ROAD
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION SW ¼ SW ¼ Sec. 16 T. 40 (N) S R. 35 E. HUMBOLDT County

PERMIT NO. 56413 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WASTE DUMP		0	85	85
GRAY CLAY		85	90	5
GRAY CLAY & GRAVEL		90	225	135
SAND & CLAY		225	230	5
GRAVEL		230	250	20
GRAVEL & BROWN CLAY		250	260	10
GRAVEL		260	380	120
RED ROCK & TAN CLAY		380	400	20
BROWN CLAY		400	410	10

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30 Inches	0 Feet	21 Feet	
21 Inches	21 Feet	66 Feet	
19 Inches	66 Feet	410 Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	125	.250	0	21
20	53	.250	0	66
14	37	.250	0	292

Perforations:
Type perforation WIRE SCREEN
Size perforation #10 SLOT
From 292 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 82
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 410 feet

9. WATER LEVEL
Static water level 223 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

Date started JULY 1, 19 95
Date completed JULY 8, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed JOHN VIERGUTZ (By driller performing actual drilling on site or contractor)
Date JULY 17, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY