WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
M/O 404320-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49766
Permit No.
Basin 067

NOTICE OF INTENT NO. 08554

1. OWNER SANTA FE PACIFIC GOLD CORP
MAILING ADDRESS 861 W 5ST 6TH ST.
WINN. NV. 89446.
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 20 T. 40 N/S R. 43 E. HUMBOLDT County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ALLUVIUM 0-390 | | 0 | 390 | 390 |
| CLAY SAND | | | | |
| GRAVEL | | | | |
| BASALT | | 390 | 410 | 20 |
| BASALT GRAVEL | X | 410 | 485 | 75 |

Date started 6-1, 1995
Date completed 6-2, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| N/A | | | |

8. WELL CONSTRUCTION
Depth Drilled 485' Feet Depth Cased 485 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 5 3/4 Inches | | 0 Feet | 485 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 1.5 | SCH 80 | PVC BLANK | 0 | 435 |
| | | | | |
| | | | | |

Perforations:
Type perforation SLOTTED 1.5" SCH 80 P.V.C
Size perforation .020
From 435 feet to 485 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 485 feet to 425 feet

9. WATER LEVEL
Static water level 316.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 72 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND DRILLING Contractor
Address P.O.BX 2786 ELKO NV. 89803 Contractor
Nevada contractor's license number 0030873 issued by the State Contractor's Board ~~0019378~~
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1288
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-2-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627