

OFFICE USE ONLY
 Log No. 49767
 Permit No. _____
 Basin. 036

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18504

1. OWNER ELKO COUNTY (TUSCARORA) ADDRESS AT WELL LOCATION None
 MAILING ADDRESS COURT HOUSE
ELKO, NV 89801
 2. LOCATION NW 1/4 NW 1/4 Sec 34 T. 40 S R. 51 E ELKO County
 PERMIT NO. 58106 Issued by Water Resources Parcel No. None Subdivision Name None

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>See original report</u>		<u>9/9/92</u>		
<u>Fault zone (gauge)</u>		<u>129</u>	<u>131</u>	<u>2</u>
<u>Quartz (Broken)</u>	<u>✓✓</u>	<u>131</u>	<u>138</u>	<u>7</u>
<u>Fault</u>	<u>✓✓</u>	<u>179</u>	<u>183</u>	<u>4</u>
<u>Fault (poor quality water, High iron content.)</u>	<u>✓✓</u>	<u>340</u>	<u>350</u>	

8. WELL CONSTRUCTION
 Depth Drilled 356 Feet Depth Cased 356 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
1.8 Inches 0 Feet 40 Feet
1.2 Inches 40 Feet 100 Feet
1.0 Inches 100 Feet 356 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>	<u>33.38</u>	<u>.250</u>	<u>0.0</u>	<u>40.65</u>
<u>6 5/8</u>	<u>17.02</u>	<u>.250</u>	<u>+2.0</u>	<u>356.00</u>

Perforations:
 Type perforation Screen
 Size perforation 0.050
 From 128 feet to 148 feet
 From 178 feet to 188 feet
 From 340 feet to 350 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 125 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 125 feet to 356 feet

9. WATER LEVEL
 Static water level 12.4 feet below land surface
 Artesian flow No G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING CO. Contractor
 Address 203 PINE ST. Contractor
ELKO, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 7-7-95

Date started 10-15, 1992
 Date completed 11-21, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>24 hr test data supplied to Elko Co. No record kept by Muth Drilling Co</u>			