49771

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49771
Permit No.
Basin 089

NOTICE OF INTENT NO. 11488

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS 310 Galetti Way Sparks NV 89431
ADDRESS AT WELL LOCATION Washoe Lake State Park, East Lake Blvd.

2. LOCATION NW ¼ NE ¼ Sec. 25 T 16 N. N/S R 19 E. Washoe County
PERMIT NO. 59868 (Issued by Water Resources) NA (Parcel No.) Wetlands Mitigation Area (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Silty Sand		1	53	52
Sandy Clay		53	72	19
Sand		72	135	63
Bedrock		135	322	187

RECEIVED 95 DEC 20 AM 11:04 STATE ENGINEERS OFFICE

Date started 11-6, 1995
Date completed 11-30, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO Testing		

8. WELL CONSTRUCTION Plugged w/ Neat Cement
Depth Drilled 322 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
48 Inches		0 Feet	57 Feet
17 Inches		57 Feet	322 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	NA	.025	0	57

Perforations:
Type perforation Plugged From 0' to 322'
Size perforation W/ Neat cement
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 57
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries (Contractor)
Address 4545 E Lincoln (Contractor)
Fresno Ca 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1732
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627