WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47775
Permit No.
Basin 101

NOTICE OF INTENT NO. 28731

1. OWNER Kevin CAWN
MAILING ADDRESS 1485 Drum ln
ADDRESS AT WELL LOCATION 1485 Drum LN FAllon

2. LOCATION SE ¼ SW ¼ Sec. 5 T 19 N/S R 29 E Churchill County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	15	15
Brown Clay		15	17	2
Grey Sands	X	17	60	33
Black Silt		60	85	25
Grey Sands		85	98	13
Black Silt		98	120	22
Brown Silt		120	130	10
Grey Sands		130	210	80
Brown clay		210	217	7
Brown Silt/clay		217	250	33
Brown clay		250	255	5
Brown silt		255	260	5
Brown Sands	X	260	270	10

Date started 11-13, 1995
Date completed 11-13, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	270	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	1/8	+1	270

Perforations:
Type perforation machine cut
Size perforation .080
From 264 feet to ~~65~~ 269 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 12' 6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.1 °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco corp (Contractor)
Address 335 W Broadway (Contractor)
FAllon
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Manzanera (By driller performing actual drilling on site or contractor)
Date 11-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627