WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49777
Permit No.
Basin 089

NOTICE OF INTENT NO. 32588

1. OWNER PAUL & PATTY LECHLER
MAILING ADDRESS 765 Brenda Way
Carson City, Nevada 89704

ADDRESS AT WELL LOCATION 765 Brenda Way
Carson City, NV 89704

2. LOCATION NE ¼ NW ¼ Sec. 30 T 17N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 050-250-10 (Parcel No.) New Washoe (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Rusty weathered decomposed granite, some clay streaks		1	11	10
Weathered granite		11	26	15
Rusty granite, some clay streaks		26	84	58
White hard granite		84	130	46
Soft zone(app. 2 GPM)	X	130	134	4
White granite		134	145	11
Fracture(app.10 GPM)	X	145	146	1
White hard granite		146	170	24
Fractured granite (app. 20 GPM)	X	170	188	18
Weathered granite		188	215	27
Fracture (NO WATER)		215	219	4
Granite		219	220	1

Date started 10-31-95, 19
Date completed 11-01-95, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
32+		

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	220 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	220

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 135 feet to 155 feet
From 195 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 foot
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow G.P.M. 32+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date November 2, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627